



CSA INTERNATIONAL

Certificate of Compliance

Certificate: 1253093

Master Contract: 212522

Project: 1695808

Date Issued: 2005/08/16

Issued to: Dynamic Fluid Measurement

12603 SW Fwy, Suite 320
Stafford, TX 77477
USA
Attention: Sam Barahim

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US'



Issued by: Rob Kohuch

Authorized by: Patricia Pasemko, Operations Manager

PRODUCTS

CLASS 2258 82 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations -
Certified to US Standards

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Groups B, C and D; Class I, Div. 1; T6:

Flow Computer - Model MICRO MV, Rated: 7 - 28 Vdc, 0.3 W,

Maximum Working Pressure 25,000 kPa (3626 psi)

Flow Computer - Model E-CHART, Rated: 7 - 28 Vdc, 0.3 W,

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Certificate: 1253093

Master Contract: 212522

Project: 1695808

Date Issued: 2005/08/16

Maximum Working Pressure 25,000 kPa (3626 psi)

Flow Computer - Model E-PLUS, Rated: 7 - 28 Vdc, 0.3 W,

Maximum Working Pressure 25,000 kPa (3626 psi)

Flow Computer - Model E-LITE, Rated: 7 - 28 Vdc, 0.3 W,

Maximum Working Pressure 25,000 kPa (3626 psi)

APPLICABLE REQUIREMENTS

The following standards were used in the evaluation of the products covered under this Report:

CSA Standard C22.2 No 0 M1991 General Requirements Canadian Electrical Code Part II.

CSA Standard C22.2 No 0.4-M1982 - Bonding and Grounding of Electrical Equipment (Protective Grounding).

CSA Standard C22.2 No 0.5-M1982 - Threaded Conduit Entries.

CSA Standard C22.2 No 30-M1986 - Explosion-proof Enclosures for Use in Class I Hazardous Locations.

CSA Standard C22.2 No 142-M1987 - Process Control Equipment.

CSA Std C22.2 No 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations



Supplement to Certificate of Compliance

Certificate: 1253093

Master Contract: 212522

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
1695808	2005/08/16	Addition of models E-Chart, E-Lite and E-Plus using enclosure certified for model Micro-MV.

History

1243093 January 10,2002 Original Certification for flow Computer Model Micro MV for Class I, Groups B, C and D, Class I Div. 2 with RTD output